

Via e-mail to: sgmps@water.ca.gov

Subject: Draft GSP Emergency Regulations Public Comment

DATE GROUNDWATER
SUSTAINABILITY PLAN
REGULATION COMMENT
RECEIVED BY DWR
03/31/2016

This is a very minor comment but as long as the well data is going to be forwarded to DWR in a tabular format for all the wells in the Plans could

Article3 Paragraph 352.6 Data Reporting Standards

Section (b)(3)(H) on page 9 of the Draft GSP Emergency Regulations add “casing material” to the specified list of well information to be included in the table for each well. Whether the well casing is Stainless Steel, PVC, or just Steel is important in many water quality studies of wells and even in some water quantity studies. By leaving it not specified as an “other information as available” it will most likely be omitted. True this data is in probably in the individual drillers log but if so much information is tabulated for each well it makes more sense for this data to be included In the larger table rather than requiring DWR to search the original drillers log for each and every well when it could easily be included in table initially.

Thank you

Lindsay A. Swain P.G. 7969, HG 1018

Lindsay Swain, PG, CHG

Senior Geohydrologist

GEOSCIENCE Support Services Inc. | Groundwater Consultants

mail to: PO Box 220 | Claremont | CA 91711

physical: 620 Arrow Highway, Suite 2000 | La Verne | CA 91750

main: 909.451.6650

lswain@geoscience-water.com

www.gssiwater.com



TO THE RECEIVER OF THIS EMAIL: Information and attachments communicated in this email is confidential and may contain material protected under attorney-client work product or exempt from disclosure by law. Unauthorized use, disclosure or copying is strictly prohibited. Please notify the sender via E-mail or telephone at the above number if you have received this communication in error.