

APPLICATION EVALUATION FORM
2014 Water-Energy Grant Program
FY 2014-2015

APPLICANT	Terrace Water Company	GRANT AMOUNT REQUESTED	\$240,000
PROPOSAL TITLE	Potable Water Pipeline Replacement	TOTAL PROPOSAL COST	\$240,000

PROPOSAL DESCRIPTION

The project would replace approximately 800 linear feet of steel and asbestos cement potable water pipe with 6-inch PVC C900 potable water pipe in order to reduce water use, energy use, and GHGs. Pipeline appurtenances (e.g., fire hydrants, valves) will also be replaced.

PROPOSAL SCORE CRITERIA

	Energy Savings (kWh/\$Million)	Water Savings (MG/\$Million)	DAC	Agreement Component	Funding Priority
Rank	Low	Medium	No	Sufficient	-
Original Value	512996	220.833			
Adjusted Value	-	-			

TECHNICAL REVIEW SUMMARY

Subject	Attachment	Application Review Comments
Calculation Review	Attachment 2	Concur with proposed water savings, energy savings, and GHG reduction calculations. No adjustments were necessary.
Agreement Components	Attachments 3, 4, and 5	Concur with agreement components and attachments meet the agreement component requirements, as outlined in the PSP.
DAC Benefit/Status	Attachment 7	All necessary disadvantaged community (DAC) benefit and status requirements were not met, as outlined in the PSP. Applicant does not demonstrate that at least 75% of a project benefit is directly received by the designated DAC.