CALIFORNIA DEPARTMENT OF WATER RESOURCES

State Water Project Power Portfolio management in an evolving power market



October 2020

The Department of Water Resources and The State Water Project (SWP)





WATER RESOURCES

Provide Leadership for Planning and Managing California's Water Resources

Ensure a Reliable Water Supply for California through Safe and Efficient Operation, Maintenance, and Management of the **State Water Project**

Utilize Leadership, Collaboration, and Strategic Partnerships to Build Capacity for Regional Water Sustainability through Local Technical and Financial Assistance

Protect Lives, Infrastructure, and Environment through the Management of Dams, Floods, and Vital Ecosystems

Increase Resiliency to Reduce Residual Risk Resulting from Floods, Drought, and Climate Change

State Water Project

- Largest state-built and operated water and power system in the U.S.
 - 36 Storage Facilities
 - 21 Pumping Plants
 - 4 Pumping-generating Plants
 - 5 Hydroelectric Generating Plants
 - 700 miles of Canals and Pipelines
- Multiple Purposes and Benefits:
 - Water Supply
 - Flood Control
 - Fish and Wildlife Mitigation and Enhancement
 - Delta Water Quality and Outflow
 - Power Generation
 - Recreation





Who Receives water from the SWP

- Serves 27 million Californians and over 750,000 acres of farmland
- Water provided to 29 State Water Contractors (SWC)
- SWC are the public agencies who signed long-term water supply contracts to receive water from the SWP

SAN FRANCISCO





SWP pumping and generating





WATER RESOURCES





CALIFORNIA DEPARTMENT OF WATER RESOURCES





CALIFORNIA DEPARTMENT OF WATER RESOURCES

SWP Power Portfolio management

(SWC Demand Profile)

SWP Historical Water Deliveries (1996-2019)



■ TABLE A ■ TURNBACK POOLS ■ ARTICLE 21 ■ CARRYOVER ■ OTHER SWP ■ WATER BANK RECOVERY



WATER RESOURCES

OTHER NSWP

SWP Power Portfolio management

(SWC Demand Profile)

SWP Systemwide Load (1996 - 2020)



Note: Projected load from June through December 2020 shown in hatched bar.



CALIFORNIA DEPARTMENT OF ATER RESOURCES

SWP Power Portfolio management

75% emissions

free resources

(Current and future resource mix)

Approval of SB100 puts California on the path to 100% zero-emission electricity by 2045



65% emissions free resources



CALIFORNIA DEPARTMENT OF ATER RESOURCES

Contracted Renewables + SWP Small Hydro 50%

Large Hydro 50%

2045

100% emissions free resources

2020 Forecast Vs Actual Load



B132-20 Load Forecast:

• 60% allocation (2.82 MAF) of water supply

2020 Updated Load Forecast (as of July 24, 2020), 90% exceedance:

- 20% allocation of Table A SWP delivery
- Delivery consists of updated demands, loss estimates, and conveyance limitations
- Pumping Load ~ 3,607 GWh (yearly total), and 1,527 GWh for July through December 2020



SWP load and generation response in supporting CAISO grid during the Heat Wave Emergency









SWP Demand Response participating load in supporting caiso grid





JRCES

SB49 - Flexible Resources Study

- DWR is assessing the potential of providing more market services to further help integrate renewable resources. DWR is investigating the following flexible operation strategies:
 - Optimizing operations of SWP generation and pumping plants
 - Real-Time Load Bidding of SWP pumps
 - Pumped Storage studies on SWP assets
 - Options for integrating more renewables generation
 - Integrating Battery-Storage with Renewables Resources
 - Offering more Ancillary Services into the power market
 - Retrofits to some pumping plants to provide more flexibility
 - Adding Pockets of Storage at strategic locations to decouple interdependencies of pumping plants



SB49 - Flexible Resources Study Schedule



SB49 - Flexible Resources Study

State Water Project- Flexible Resources Study Planning Tracks	Target Date	Progress	Dates						
			Q1-2020	Q2-2020	Q3-2020	Q4-2020	Q1-2021	Q2-2021	Q3-2021
4. Integrating Battery Storage with Renewable Resources	Oct-21	26%							
A. Concept Discussion, Scoping, and Expectations	Jan-21	60%							
B. Model Development - Storage Integration for load shifting	Mar-21	25%							
C. Physical vs. Battery Storage Integration Analysis	Jun-21	10%							
D. Assessing feasibility, Timing and potential for Integrating BESS	Oct-21	10%							
5. Retrofits to select pumping plants to provide more flexibility - Variable Speed Pump	Oct-21	36%							
A. Concept Discussion, Scoping, and Expectations	Nov-20	60%							
B. Review SWP Facilities and Retrofit Scope	Dec-20	60%							
C. Review OEM Submitted Proposal	Mar-21	8%							
D Assess Proposal - Economic Benefits Investigation	Jun-21	25%							
E. Assess current and future Market design needs for VFD vs Revenue requirement of development	Oct-21	25%							
6. SWP Hydraulic and Transient Modeling, and Aqueduct Stability	Oct-21	48%							
A. Concept Discussion, Scoping, and Expectations	Nov-20	60%							
B. HEC-RAS Model Development	Mar-21	70%							
C. Operational/System Response Analysis of SWP Delivery System	Apr-21	30%							
D. Identify SWP aqueduct Operational limits from add/drop pump load	Oct-21	30%							
7. Real-Time Load Bidding - Offering More Ancillary Services –	Oct-21	34%							
A. Concept Discussion, Scoping, and Expectations	Mar-21	25%							
B. Model Development - Potential Improvements Investigation	Apr-21	60%							
C. Assess current and future market opportunities and potential	Mag-21	30%							
D. Consult with CAISO to identify need for capacity, seasonality, and location	Oct-21	20%							
8. Adding Pockets of Storage at Strategic Locations	Oct-21	38%							
A. Concept Discussion, scoping, and Expectations (HEC-RAS Model)	Mar-21	90%							
B. HEC-RAS Model modifications to test added storage	Mar-21	20%							
C. Perform Operational studies to assess increased SWP operational flexibility	Mar-21	20%							
D. Viability Investigation of Adding New Pockets of Water Storage	Oct-21	20%							
9. Integration of On-Site Solar generation at Pumping Plants- Behind The Meter (BTM)	Oct-21	22%							
A. Concept Discussion, Scoping, and Expectations	Mar-21	45%					L L		
B. Assessment of potential Development	Mar-21	15%							
C. Identifying viable SWP Pumping Plants for Integration	Jun-21	20%							
D. Secure CAISO Buy in on concept	Jun-21	30%							
E. Economic and GHG footprint, and Grid benefits Analusis	Oct-21	0%							and the second second
	to and the second state of the second state	de la constante	c++						



WATER RESOURCES



Flexible Resources Study

(Reoperations of Edmonston and Valley String)

Historical vs Optimized Load Dispatch for Buena Vista on Mar 10, 2004

Valley String Avg. Energy Prices (March 2016)





Historical Load Distribution

Optimized Load Distribution

Ave. VS LMPs for March 2016



Flexible Resources Study (Reoperations of Pearblossom – emissions reductions)





CALIFORNIA DEPARTMENT OF ATER RESOURCES

Flexible Resources Study (Pumpback Reoperations of Hyatt-Thermalito)



Figure 2.2. Example flow schedules resulting from the optimization for Jan 6, 2030.



Flexible Resources Study

(Retrofits of some existing pumps to Variable speed pumps)

Grimsel 2 pumped-storage plant (Switzerland):

The concept of running the synchronous motor/generator at variable speed by feeding its stator with a variable frequency overcomes the limitations of the previous fixed-speed design, providing valuable operational benefits.

- Optimized use of excessive energy on the grid: continuously 1. adjustable energy consumption is provided in pump operation, increasing the amount of stored water.
- Quick start of the pump without water loss: the unit in pump 2. mode is now started by means of the converter within 60 seconds, thereby saving large amounts of valuable stored water.
- Reactive power compensation: the power converter can be 3. operated without the machine as a reactive power compensation system, offering up to 100MVar instantaneous support to the grid.

Because it was not necessary to modify the existing generator and step-up transformer, the installation of the frequency conversion unit was possible without impact on the plant's operation, and it's hookup caused minimum interruption of service.





Note: Do not reproduce; proprietary information



Key data: PCS 8000 frequency converter at Grimsel 2					
Rated power	100 MVA				
Input voltage, current	13.5 kV, 4650 A, 50 Hz				
Output voltage, current for pump operation	10.8 - 13.5 kV, 4650 A, 40 - 51 Hz				
Output voltage for start-up	0 - 13.5 kV, 0 - 51 Hz				

Flexible Resources Study

(Retrofits of some existing pumps to Variable speed pumps)

Chrisman Large Unit Proposed Variable Power Ranges





FR RFS(

JRCES



CALIFORNIA DEPARTMENT OF WATER RESOURCES

Thank You

Questions?

