

Appendix 5A2

Chloride

This appendix is entirely new for the Final Environmental Impact Report (FEIR) and was not included as part of the Draft Environmental Impact Report. This appendix replaces Appendix 5A1 in its entirety in the FEIR. It is presented without strikethrough and underline for clarity and readability.

5A.1 Appendix Overview

The information contained in this appendix supports the quantitative assessment of the Proposed Project's effects on chloride concentrations at Sacramento–San Joaquin Delta (Delta) assessment locations presented in Chapter 5, "Surface Water Quality." Specifically, this appendix presents the following information.

- The source water concentrations used in the mass-balance modeling of chloride at the Delta assessment locations.
- Tables and figures presenting modeled concentrations at the Delta assessment locations for Baseline Conditions and the Proposed Project.

Chapter 5, "Surface Water Quality," summarizes information contained in the tables and figures presented in this appendix to make determinations regarding the potential for the Proposed Project to result in significant impacts on chloride at Delta assessment locations.

5A.2 Source Water Concentrations

An input to the mass-balance calculation of chloride concentrations at the Delta assessment locations is the concentration of chloride in the primary source waters to the Delta: SAC, SJR, YOL, EST, BAY, and AGR. The concentrations of chloride for all source waters except the San Joaquin River were based on historical data. Table 5A-1 provides summary statistics for the primary source water concentrations, as well as information on the source of the data. Due to data availability, Yolo Bypass concentrations were set equal to Sacramento River concentrations, which is the source of flows to the Yolo Bypass.

Table 5A-1. Source Water Concentrations for Chloride (in milligrams per liter)

| Data Parameter | Sacramento River | San Joaquin River | San Francisco Bay | Eastside Tributaries | Delta Agriculture Return Waters |
|---|--|-------------------------------|--|---|--|
| Average | 6.4 | 76 | 6,507 | 2.4 | 156 |
| Minimum | 1.0 | 1.0 | 8.0 | 0.3 | 3.0 |
| Maximum | 33 | 221 | 12,600 | 10 | 2,010 |
| 75th percentile | 8.0 | 106 | 9,255 | 3.0 | 184 |
| 99th percentile | 12 | 181 | 12,464 | 8.7 | 1,148 |
| Data source | CEDEN, DWR | CEDEN, DWR | CEDEN | CEDEN, USGS | DWR |
| Station(s) | Sacramento River at Greene's Landing, Sacramento River at Hood | San Joaquin River at Vernalis | Suisun Bay at Bulls Head near Martinez | Mokelumne River, Cosumnes River | Multiple – see narrative description below |
| Date range | 1980–2020 | 1980–2020 | 1980–2007 | 1952–2015 | 1985–2004 |
| Non-detect results replaced with reporting limit for statistics | No | No | No | None | None |
| Data omitted | None | None | None | Single <0.1 value from each dataset, 0 values from Cosumnes River | Yes – see narrative description below |
| Number of data points | 1,330 | 1,232 | 319 | 481 | 1,576 |

Sources: California Environmental Data Exchange Network 2020; California Department of Water Resources 2020; U.S. Geological Survey 2020.

CEDEN = California Environmental Data Exchange Network; DWR = California Department of Water Resources; USGS = U.S. Geological Survey.

Each source water dataset was evaluated to determine whether the primary source water concentration should be represented by a single value or a different value for each month. Analysis of the Sacramento River (Kruskal Wallis; $p < 0.05$), eastside tributaries (Kruskal Wallis; $p < 0.05$), and Delta agricultural return waters (Kruskal Wallis; $p < 0.05$) datasets indicated significant differences in concentration by month. Due to the presence of a distinct monthly pattern in Sacramento River, eastside tributaries, and Delta agricultural return waters, monthly average concentrations were used for these locations in the mass-balance calculation. Table 5A-2, Table 5A-3, and Table 5A-4 present monthly average chloride concentrations for the Sacramento River, eastside tributaries, and Delta agriculture return waters used in the mass-balance calculation, respectively.

The source water concentrations for the San Joaquin River and San Francisco Bay were calculated in a different manner. Because San Joaquin River and San Francisco Bay chloride concentrations are closely related to flow, in addition to time of year, concentrations were calculated from DSM2-modeled electrical conductivity (EC). The EC-chloride regression equations defined below were applied to each modeled monthly average EC value for water years 1922–2021 to develop monthly average chloride concentrations for the modeled period, resulting in a time-series of monthly average chloride concentrations consisting of 1,188 values (i.e., 12 months times 99 water years). In the following equation, Cl is the chloride concentration in milligrams per liter (mg/L) and EC is in micromhos per centimeter ($\mu\text{mhos/cm}$).

$$\text{San Joaquin River at Vernalis } Cl = 0.1845 * EC \text{ at Vernalis} - 23$$

$$\text{San Francisco Bay at Martinez } Cl = 0.285 * EC \text{ at Martinez} - 50$$

The monthly average chloride concentrations were input as C_{SJR} and C_{BAY} in the mass-balance equation.

Table 5A-2. Monthly Average Source Water Chloride Concentrations for the Sacramento River (in milligrams per liter)

| Data Parameter | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Average concentration | 7.1 | 6.9 | 6.0 | 5.8 | 6.5 | 6.1 | 5.0 | 5.7 | 7.2 | 6.1 | 7.1 | 7.0 |
| Number of data points | 107 | 109 | 112 | 110 | 112 | 113 | 112 | 117 | 116 | 114 | 104 | 104 |

Table 5A-3. Monthly Average Source Water Chloride Concentrations for the Eastside Tributaries (in milligrams per liter)

| Data Parameter | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Average concentration | 2.7 | 2.6 | 2.4 | 2.0 | 1.9 | 2.0 | 1.8 | 2.1 | 2.0 | 2.5 | 3.1 | 2.7 |
| Number of data points | 40 | 30 | 51 | 36 | 34 | 42 | 35 | 25 | 54 | 31 | 31 | 43 |

Table 5A-4. Monthly Average Source Water Chloride Concentrations for Delta Agricultural Return Waters (in milligrams per liter)

| Data Parameter | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Average concentration | 198 | 223 | 175 | 188 | 133 | 123 | 115 | 121 | 170 | 170 | 144 | 120 |
| Number of data points | 235 | 55 | 100 | 233 | 65 | 183 | 221 | 184 | 26 | 186 | 37 | 51 |

Agricultural return drains are distributed unevenly throughout the Delta. Water quality associated with these drains varies depending on the specific location of the drain within the Delta and largely coincides with the water quality of the water that is withdrawn from the Delta for application onto agricultural lands. To characterize chloride concentrations in agricultural drain water as a whole, the following process was followed.

1. All agricultural drain data from the DWR Water Data Library, which had historical chloride data, were compiled.
2. All agricultural drain data were pooled, and the results summarized in Table 5A-1.

Data for the Byron Tract #2 (16,800 mg/L on May 29, 1996) and Byron Tract #3 (24,000 micrograms per liter [$\mu\text{g/L}$] on May 29, 1996) agricultural drains in the west Delta were omitted from the database due to their reported values being substantially outside the distribution of all other values.

5A.3 Modeling Results

The modeled monthly average concentrations of chloride at each Delta assessment location are presented on the following pages in tables and figures, in the following formats.

- Tables
 - Probability of exceedance of the monthly average concentration for water years 1922–2021.
 - Average of monthly average concentrations for water years 1922–2021 and by water year type: Wet, Above Normal, Below Normal, Dry, and Critical.
 - Results shown for Baseline Conditions and the Proposed Project, and the Proposed Project minus Baseline Conditions.
- Monthly Average Plots
 - Average of monthly average concentrations for water years 1922–2021 and by water year type: Wet, Above Normal, Below Normal, Dry, and Critical.
 - Baseline Conditions and the Proposed Project shown on the same plot.
- Exceedance Plots
 - Probability exceedance of the monthly average concentrations for water years 1922–2021.
 - Baseline Conditions and the Proposed Project shown on the same plot.

Table 5A-5a. Barker Slough at North Bay Aqueduct, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 26 | 28 | 30 | 50 | 68 | 52 | 39 | 24 | 20 | 19 | 20 | 26 |
| 1% | 26 | 28 | 27 | 49 | 63 | 42 | 38 | 23 | 20 | 17 | 19 | 26 |
| 5% | 25 | 27 | 27 | 44 | 50 | 39 | 36 | 22 | 19 | 17 | 18 | 26 |
| 10% | 25 | 26 | 26 | 40 | 47 | 38 | 35 | 22 | 18 | 16 | 18 | 24 |
| 25% | 23 | 24 | 24 | 34 | 42 | 34 | 31 | 20 | 16 | 14 | 15 | 21 |
| 50% | 21 | 22 | 22 | 25 | 28 | 26 | 27 | 18 | 15 | 14 | 14 | 20 |
| 75% | 20 | 20 | 20 | 20 | 21 | 20 | 25 | 18 | 14 | 13 | 14 | 20 |
| 99.9% | 18 | 19 | 18 | 16 | 17 | 17 | 18 | 15 | 13 | 11 | 13 | 18 |

Table 5A-5b. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 21 | 23 | 22 | 28 | 31 | 27 | 28 | 19 | 16 | 14 | 15 | 21 |
| Wet Water Years | 21 | 23 | 23 | 24 | 25 | 23 | 26 | 18 | 14 | 13 | 14 | 20 |
| Above Normal Water Years | 22 | 23 | 23 | 31 | 35 | 28 | 28 | 18 | 15 | 13 | 14 | 20 |
| Below Normal Water Years | 21 | 23 | 22 | 27 | 30 | 25 | 26 | 19 | 16 | 14 | 14 | 21 |
| Dry Water Years | 21 | 22 | 22 | 28 | 33 | 30 | 29 | 20 | 16 | 14 | 15 | 21 |
| Critical Water Years | 23 | 23 | 22 | 35 | 41 | 34 | 32 | 21 | 19 | 17 | 18 | 25 |

Table 5A-6a. Barker Slough at North Bay Aqueduct, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 26 | 28 | 30 | 50 | 68 | 52 | 39 | 24 | 20 | 19 | 20 | 26 |
| 1% | 26 | 28 | 27 | 49 | 63 | 42 | 38 | 23 | 20 | 17 | 19 | 26 |
| 5% | 25 | 26 | 27 | 44 | 50 | 39 | 36 | 22 | 19 | 17 | 18 | 26 |
| 10% | 24 | 26 | 26 | 40 | 47 | 38 | 35 | 22 | 18 | 16 | 18 | 24 |
| 25% | 23 | 24 | 24 | 34 | 42 | 34 | 31 | 20 | 16 | 14 | 15 | 21 |
| 50% | 21 | 22 | 22 | 25 | 28 | 26 | 27 | 18 | 15 | 14 | 14 | 20 |
| 75% | 20 | 20 | 20 | 20 | 21 | 20 | 25 | 18 | 14 | 13 | 14 | 20 |
| 99.9% | 18 | 19 | 18 | 16 | 17 | 17 | 18 | 15 | 13 | 11 | 13 | 18 |

Table 5A-6b. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 21 | 23 | 22 | 28 | 31 | 27 | 28 | 19 | 16 | 14 | 15 | 21 |
| Wet Water Years | 21 | 23 | 23 | 24 | 25 | 23 | 27 | 18 | 14 | 13 | 14 | 20 |
| Above Normal Water Years | 22 | 23 | 23 | 31 | 35 | 28 | 28 | 18 | 15 | 13 | 14 | 20 |
| Below Normal Water Years | 21 | 23 | 22 | 27 | 30 | 25 | 26 | 19 | 16 | 14 | 14 | 21 |
| Dry Water Years | 21 | 22 | 22 | 28 | 34 | 30 | 29 | 20 | 16 | 14 | 15 | 21 |
| Critical Water Years | 23 | 23 | 22 | 35 | 40 | 34 | 32 | 21 | 19 | 17 | 18 | 25 |

Table 5A-6c. Barker Slough at North Bay Aqueduct, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 1% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 25% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 50% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 75% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table 5A-6d. Barker Slough at North Bay Aqueduct, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Wet Water Years | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Above Normal Water Years | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Below Normal Water Years | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Dry Water Years | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Critical Water Years | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table 5A-7a. San Joaquin River at Empire Tract, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 99 | 115 | 136 | 129 | 112 | 67 | 56 | 44 | 51 | 60 | 70 | 94 |
| 1% | 99 | 109 | 133 | 107 | 90 | 62 | 56 | 44 | 50 | 48 | 65 | 84 |
| 5% | 88 | 98 | 122 | 94 | 75 | 51 | 50 | 40 | 47 | 44 | 53 | 70 |
| 10% | 77 | 90 | 102 | 88 | 58 | 47 | 46 | 39 | 40 | 40 | 49 | 62 |
| 25% | 55 | 56 | 86 | 68 | 51 | 42 | 44 | 36 | 32 | 28 | 40 | 54 |
| 50% | 44 | 48 | 67 | 50 | 43 | 35 | 38 | 32 | 28 | 23 | 30 | 46 |
| 75% | 25 | 33 | 33 | 34 | 34 | 29 | 25 | 22 | 24 | 17 | 20 | 21 |
| 99.9% | 9 | 22 | 9 | 5 | 5 | 4 | 3 | 2 | 2 | 3 | 6 | 18 |

Table 5A-7b. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 44 | 50 | 64 | 53 | 43 | 34 | 33 | 28 | 27 | 25 | 32 | 41 |
| Wet Water Years | 38 | 43 | 43 | 36 | 28 | 22 | 17 | 15 | 16 | 17 | 20 | 21 |
| Above Normal Water Years | 48 | 57 | 75 | 47 | 45 | 38 | 36 | 28 | 26 | 19 | 19 | 21 |
| Below Normal Water Years | 41 | 46 | 67 | 53 | 46 | 39 | 38 | 30 | 29 | 23 | 34 | 54 |
| Dry Water Years | 42 | 47 | 77 | 66 | 50 | 37 | 41 | 36 | 29 | 29 | 41 | 49 |
| Critical Water Years | 61 | 70 | 76 | 71 | 54 | 44 | 44 | 37 | 41 | 39 | 46 | 63 |

Table 5A-8a. San Joaquin River at Empire Tract, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 103 | 116 | 134 | 128 | 112 | 67 | 57 | 45 | 55 | 59 | 70 | 94 |
| 1% | 100 | 109 | 131 | 102 | 85 | 61 | 56 | 44 | 50 | 48 | 62 | 84 |
| 5% | 86 | 98 | 120 | 95 | 71 | 52 | 50 | 39 | 46 | 44 | 54 | 69 |
| 10% | 74 | 89 | 102 | 88 | 60 | 49 | 46 | 38 | 40 | 40 | 50 | 61 |
| 25% | 54 | 57 | 86 | 69 | 53 | 44 | 44 | 36 | 32 | 28 | 41 | 55 |
| 50% | 46 | 48 | 68 | 50 | 43 | 36 | 38 | 31 | 29 | 22 | 31 | 46 |
| 75% | 26 | 33 | 34 | 34 | 35 | 29 | 25 | 22 | 24 | 18 | 21 | 22 |
| 99.9% | 9 | 22 | 9 | 5 | 5 | 4 | 3 | 2 | 2 | 3 | 6 | 17 |

Table 5A-8b. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 44 | 50 | 65 | 53 | 43 | 35 | 34 | 27 | 27 | 24 | 33 | 42 |
| Wet Water Years | 38 | 43 | 43 | 36 | 28 | 22 | 17 | 14 | 16 | 17 | 21 | 22 |
| Above Normal Water Years | 49 | 57 | 76 | 48 | 45 | 39 | 36 | 27 | 27 | 19 | 21 | 22 |
| Below Normal Water Years | 42 | 47 | 67 | 53 | 47 | 41 | 39 | 29 | 29 | 23 | 35 | 53 |
| Dry Water Years | 40 | 46 | 77 | 65 | 50 | 38 | 42 | 35 | 29 | 28 | 43 | 52 |
| Critical Water Years | 61 | 70 | 77 | 72 | 54 | 44 | 44 | 37 | 41 | 39 | 46 | 63 |

Table 5A-8c. San Joaquin River at Empire Tract, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 3 | 1 | -3 | 0 | 0 | 0 | 1 | 1 | 4 | -1 | 0 | 0 |
| 1% | 0 | 0 | -2 | -5 | -5 | -1 | 0 | 0 | 1 | 0 | -4 | 0 |
| 5% | -2 | 0 | -2 | 0 | -4 | 1 | 0 | -2 | 0 | 0 | 1 | -1 |
| 10% | -3 | -2 | 0 | 0 | 3 | 2 | 0 | -1 | 0 | 0 | 1 | 0 |
| 25% | 0 | 1 | 0 | 1 | 1 | 2 | 0 | -1 | 0 | 0 | 1 | 1 |
| 50% | 1 | 0 | 1 | 1 | 1 | 1 | 1 | -1 | 0 | 0 | 1 | 1 |
| 75% | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 1 | 0 | 1 | 0 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table 5A-8d. San Joaquin River at Empire Tract, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 0 | 0 | 0 | 0 | 1 | 1 | 0 | -1 | 0 | 0 | 1 | 1 |
| Wet Water Years | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 1 |
| Above Normal Water Years | 1 | 0 | 1 | 1 | 1 | 1 | 0 | -1 | 0 | 0 | 2 | 1 |
| Below Normal Water Years | 0 | 0 | 0 | 0 | 1 | 2 | 0 | -1 | 0 | 0 | 1 | -1 |
| Dry Water Years | -1 | 0 | -1 | -1 | 0 | 2 | 1 | 0 | 0 | 0 | 2 | 3 |
| Critical Water Years | 0 | 0 | 1 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table 5A-9a. Banks Pumping Plant, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 166 | 185 | 196 | 194 | 140 | 110 | 80 | 67 | 97 | 144 | 155 | 183 |
| 1% | 166 | 177 | 194 | 169 | 134 | 105 | 78 | 64 | 83 | 112 | 149 | 174 |
| 5% | 156 | 163 | 178 | 155 | 116 | 95 | 70 | 59 | 73 | 96 | 121 | 160 |
| 10% | 148 | 157 | 160 | 146 | 103 | 83 | 68 | 56 | 62 | 87 | 108 | 146 |
| 25% | 134 | 124 | 142 | 123 | 85 | 74 | 64 | 53 | 46 | 53 | 91 | 127 |
| 50% | 115 | 106 | 121 | 93 | 70 | 65 | 57 | 42 | 41 | 41 | 62 | 105 |
| 75% | 33 | 49 | 65 | 63 | 53 | 39 | 27 | 25 | 33 | 26 | 36 | 47 |
| 99.9% | 11 | 26 | 7 | 2 | 1 | 2 | 0 | 0 | 0 | 2 | 7 | 22 |

Table 5A-9b. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 90 | 93 | 109 | 91 | 68 | 57 | 46 | 38 | 39 | 45 | 66 | 92 |
| Wet Water Years | 80 | 80 | 75 | 59 | 41 | 30 | 19 | 17 | 19 | 22 | 32 | 40 |
| Above Normal Water Years | 95 | 94 | 126 | 83 | 70 | 60 | 44 | 34 | 34 | 28 | 37 | 48 |
| Below Normal Water Years | 81 | 87 | 111 | 93 | 72 | 62 | 49 | 38 | 42 | 45 | 77 | 133 |
| Dry Water Years | 88 | 91 | 126 | 114 | 82 | 70 | 63 | 53 | 45 | 59 | 94 | 116 |
| Critical Water Years | 122 | 125 | 134 | 123 | 91 | 82 | 68 | 57 | 67 | 81 | 94 | 132 |

Table 5A-10a. Banks Pumping Plant, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 167 | 185 | 196 | 194 | 134 | 109 | 79 | 66 | 108 | 144 | 147 | 183 |
| 1% | 166 | 177 | 193 | 169 | 123 | 106 | 78 | 64 | 83 | 113 | 141 | 169 |
| 5% | 154 | 164 | 177 | 155 | 116 | 94 | 71 | 59 | 74 | 92 | 125 | 151 |
| 10% | 148 | 155 | 160 | 148 | 103 | 86 | 68 | 56 | 61 | 83 | 115 | 144 |
| 25% | 137 | 126 | 142 | 122 | 91 | 76 | 64 | 52 | 45 | 54 | 92 | 132 |
| 50% | 118 | 107 | 121 | 95 | 71 | 67 | 58 | 41 | 42 | 40 | 62 | 109 |
| 75% | 34 | 48 | 66 | 64 | 56 | 40 | 28 | 24 | 34 | 26 | 39 | 53 |
| 99.9% | 11 | 26 | 7 | 2 | 1 | 2 | 0 | 0 | 0 | 2 | 7 | 21 |

Table 5A-10b. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 91 | 93 | 109 | 92 | 69 | 59 | 46 | 37 | 39 | 44 | 68 | 95 |
| Wet Water Years | 81 | 82 | 75 | 59 | 41 | 30 | 20 | 16 | 19 | 22 | 35 | 44 |
| Above Normal Water Years | 97 | 94 | 127 | 85 | 72 | 61 | 44 | 32 | 35 | 28 | 43 | 53 |
| Below Normal Water Years | 82 | 87 | 111 | 94 | 74 | 65 | 49 | 39 | 41 | 43 | 78 | 131 |
| Dry Water Years | 88 | 91 | 126 | 113 | 85 | 73 | 64 | 52 | 45 | 58 | 98 | 124 |
| Critical Water Years | 124 | 126 | 134 | 127 | 92 | 83 | 67 | 57 | 67 | 82 | 94 | 132 |

Table 5A-10c. Banks Pumping Plant, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 0 | 0 | 0 | 0 | -7 | -1 | -1 | 0 | 11 | 0 | -8 | -1 |
| 1% | 0 | 0 | -1 | 1 | -11 | 1 | 0 | 0 | 0 | 0 | -8 | -5 |
| 5% | -2 | 1 | -2 | 0 | 0 | -1 | 0 | 0 | 1 | -4 | 4 | -9 |
| 10% | 0 | -2 | 0 | 2 | 0 | 3 | 0 | 0 | 0 | -4 | 7 | -2 |
| 25% | 3 | 2 | 0 | -1 | 5 | 2 | 1 | -1 | -1 | 2 | 1 | 5 |
| 50% | 2 | 1 | 0 | 2 | 1 | 2 | 1 | -1 | 1 | -1 | 0 | 5 |
| 75% | 2 | -1 | 1 | 1 | 2 | 0 | 1 | -1 | 1 | -1 | 3 | 6 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -1 |

Table 5A-10d. Banks Pumping Plant, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 1 | 0 | 0 | 1 | 2 | 1 | 0 | 0 | 0 | -1 | 3 | 3 |
| Wet Water Years | 1 | 1 | 0 | 0 | 0 | 0 | 0 | -1 | 1 | 0 | 3 | 5 |
| Above Normal Water Years | 2 | -1 | 1 | 2 | 2 | 1 | 1 | -2 | 1 | 0 | 6 | 5 |
| Below Normal Water Years | 1 | 0 | 0 | 1 | 2 | 3 | 1 | 0 | 0 | -2 | 1 | -2 |
| Dry Water Years | 0 | 0 | -1 | -1 | 3 | 2 | 1 | 0 | 1 | -1 | 4 | 8 |
| Critical Water Years | 2 | 1 | 0 | 3 | 1 | 1 | 0 | 0 | 0 | 1 | 0 | 0 |

Table 5A-11a. Jones Pumping Plant, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 159 | 178 | 185 | 184 | 143 | 115 | 78 | 66 | 95 | 138 | 153 | 179 |
| 1% | 158 | 170 | 178 | 162 | 137 | 112 | 77 | 64 | 83 | 112 | 147 | 167 |
| 5% | 144 | 155 | 166 | 151 | 118 | 102 | 72 | 61 | 73 | 96 | 120 | 150 |
| 10% | 141 | 151 | 154 | 138 | 105 | 90 | 70 | 59 | 63 | 87 | 108 | 143 |
| 25% | 125 | 124 | 136 | 123 | 91 | 80 | 68 | 54 | 49 | 56 | 91 | 121 |
| 50% | 107 | 107 | 117 | 97 | 75 | 71 | 59 | 42 | 45 | 45 | 62 | 103 |
| 75% | 42 | 60 | 72 | 70 | 58 | 40 | 26 | 24 | 37 | 34 | 42 | 50 |
| 99.9% | 10 | 30 | 8 | 3 | 1 | 2 | 1 | 1 | 1 | 1 | 5 | 23 |

Table 5A-11b. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 89 | 98 | 107 | 93 | 71 | 61 | 47 | 38 | 41 | 48 | 67 | 91 |
| Wet Water Years | 79 | 86 | 78 | 63 | 43 | 31 | 19 | 17 | 20 | 26 | 36 | 44 |
| Above Normal Water Years | 93 | 102 | 123 | 88 | 75 | 63 | 44 | 34 | 38 | 36 | 43 | 52 |
| Below Normal Water Years | 80 | 93 | 107 | 95 | 76 | 67 | 51 | 39 | 45 | 49 | 77 | 127 |
| Dry Water Years | 87 | 95 | 122 | 114 | 86 | 77 | 66 | 54 | 49 | 61 | 93 | 114 |
| Critical Water Years | 116 | 126 | 128 | 122 | 95 | 90 | 70 | 58 | 68 | 81 | 93 | 129 |

Table 5A-12a. Jones Pumping Plant, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 159 | 178 | 185 | 184 | 144 | 115 | 78 | 66 | 105 | 140 | 145 | 179 |
| 1% | 159 | 170 | 177 | 162 | 134 | 113 | 78 | 64 | 83 | 112 | 138 | 162 |
| 5% | 146 | 162 | 165 | 153 | 118 | 101 | 72 | 61 | 74 | 92 | 125 | 144 |
| 10% | 138 | 151 | 156 | 144 | 104 | 92 | 70 | 59 | 63 | 82 | 115 | 139 |
| 25% | 128 | 126 | 134 | 121 | 96 | 81 | 67 | 54 | 49 | 58 | 91 | 127 |
| 50% | 109 | 108 | 118 | 98 | 76 | 73 | 59 | 41 | 45 | 45 | 63 | 107 |
| 75% | 42 | 60 | 72 | 71 | 59 | 40 | 27 | 24 | 37 | 33 | 45 | 56 |
| 99.9% | 10 | 30 | 8 | 3 | 1 | 2 | 1 | 1 | 1 | 1 | 5 | 22 |

Table 5A-12b. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 89 | 98 | 107 | 94 | 73 | 62 | 47 | 38 | 41 | 48 | 70 | 94 |
| Wet Water Years | 79 | 87 | 78 | 63 | 43 | 31 | 19 | 16 | 20 | 26 | 38 | 48 |
| Above Normal Water Years | 95 | 103 | 124 | 90 | 77 | 64 | 44 | 33 | 38 | 36 | 48 | 56 |
| Below Normal Water Years | 81 | 93 | 107 | 96 | 78 | 69 | 51 | 39 | 45 | 47 | 78 | 125 |
| Dry Water Years | 87 | 95 | 121 | 114 | 89 | 78 | 67 | 54 | 49 | 60 | 97 | 121 |
| Critical Water Years | 117 | 127 | 128 | 125 | 96 | 91 | 70 | 58 | 68 | 82 | 94 | 129 |

Table 5A-12c. Jones Pumping Plant, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 0 | 0 | 0 | 0 | 0 | -1 | 0 | 0 | 10 | 2 | -8 | -1 |
| 1% | 0 | 1 | -1 | 0 | -3 | 1 | 0 | 0 | 0 | 0 | -8 | -5 |
| 5% | 1 | 7 | -1 | 2 | 0 | -1 | 0 | 0 | 1 | -4 | 5 | -6 |
| 10% | -3 | 0 | 2 | 5 | -1 | 3 | 0 | 0 | -1 | -5 | 7 | -4 |
| 25% | 3 | 2 | -2 | -2 | 5 | 1 | -1 | 0 | 0 | 2 | 1 | 6 |
| 50% | 2 | 1 | 1 | 1 | 1 | 2 | 0 | -1 | 1 | -1 | 1 | 3 |
| 75% | 1 | 0 | 0 | 1 | 1 | 0 | 0 | 0 | 1 | -1 | 3 | 5 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -1 |

Table 5A-12d. Jones Pumping Plant, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 1 | 0 | 0 | 1 | 1 | 1 | 0 | 0 | 0 | 0 | 2 | 3 |
| Wet Water Years | 0 | 1 | 0 | 0 | 0 | 0 | 0 | -1 | 0 | 0 | 2 | 4 |
| Above Normal Water Years | 1 | 1 | 1 | 2 | 2 | 1 | 0 | -1 | 1 | 0 | 4 | 5 |
| Below Normal Water Years | 1 | 0 | 0 | 1 | 2 | 2 | 0 | 0 | 0 | -2 | 1 | -2 |
| Dry Water Years | 0 | 0 | -1 | 0 | 2 | 2 | 0 | 0 | 1 | -1 | 4 | 7 |
| Critical Water Years | 1 | 1 | 0 | 3 | 1 | 1 | 0 | 0 | 0 | 1 | 0 | 0 |

Table 5A-13a. San Joaquin River at Antioch, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 2109 | 2160 | 1633 | 1455 | 686 | 553 | 553 | 803 | 1231 | 1394 | 1464 | 1891 |
| 1% | 2062 | 2033 | 1630 | 1353 | 631 | 528 | 521 | 791 | 1139 | 1270 | 1437 | 1876 |
| 5% | 2025 | 1900 | 1525 | 1029 | 543 | 292 | 329 | 654 | 985 | 1170 | 1354 | 1778 |
| 10% | 1882 | 1793 | 1404 | 885 | 325 | 196 | 221 | 380 | 788 | 1074 | 1281 | 1731 |
| 25% | 1585 | 1552 | 1160 | 554 | 143 | 53 | 95 | 177 | 369 | 718 | 1115 | 1568 |
| 50% | 1259 | 1088 | 734 | 175 | 28 | 24 | 26 | 36 | 224 | 445 | 832 | 1194 |
| 75% | 247 | 678 | 223 | 24 | 22 | 21 | 21 | 20 | 32 | 196 | 461 | 338 |
| 99.9% | 17 | 18 | 17 | 14 | 15 | 13 | 11 | 11 | 11 | 13 | 17 | 17 |

Table 5A-13b. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 998 | 1082 | 725 | 332 | 121 | 71 | 84 | 141 | 289 | 497 | 791 | 995 |
| Wet Water Years | 825 | 807 | 285 | 65 | 24 | 20 | 19 | 23 | 49 | 133 | 357 | 275 |
| Above Normal Water Years | 1020 | 1065 | 703 | 125 | 25 | 22 | 23 | 29 | 106 | 214 | 484 | 316 |
| Below Normal Water Years | 868 | 1017 | 835 | 334 | 83 | 32 | 40 | 65 | 254 | 489 | 862 | 1242 |
| Dry Water Years | 967 | 1171 | 915 | 561 | 196 | 90 | 112 | 179 | 381 | 752 | 1101 | 1547 |
| Critical Water Years | 1518 | 1573 | 1159 | 657 | 317 | 227 | 269 | 489 | 783 | 1032 | 1296 | 1727 |

Table 5A-14a. San Joaquin River at Antioch, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 2107 | 2161 | 1630 | 1458 | 629 | 534 | 549 | 926 | 1336 | 1406 | 1467 | 1893 |
| 1% | 2062 | 2033 | 1626 | 1357 | 623 | 518 | 523 | 775 | 1142 | 1280 | 1446 | 1865 |
| 5% | 2004 | 1916 | 1478 | 1020 | 507 | 284 | 336 | 665 | 991 | 1177 | 1345 | 1797 |
| 10% | 1882 | 1798 | 1409 | 860 | 349 | 158 | 231 | 404 | 821 | 1079 | 1267 | 1723 |
| 25% | 1607 | 1569 | 1156 | 581 | 144 | 49 | 82 | 168 | 359 | 720 | 1185 | 1599 |
| 50% | 1370 | 1122 | 741 | 177 | 27 | 24 | 26 | 41 | 205 | 441 | 802 | 1278 |
| 75% | 253 | 663 | 224 | 24 | 22 | 21 | 21 | 20 | 28 | 187 | 502 | 365 |
| 99.9% | 17 | 18 | 17 | 14 | 15 | 13 | 11 | 11 | 11 | 13 | 17 | 18 |

Table 5A-14b. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 1021 | 1087 | 723 | 331 | 117 | 67 | 82 | 145 | 283 | 491 | 808 | 1027 |
| Wet Water Years | 852 | 815 | 281 | 60 | 23 | 20 | 19 | 26 | 45 | 130 | 395 | 307 |
| Above Normal Water Years | 1027 | 1047 | 698 | 128 | 25 | 22 | 22 | 32 | 95 | 206 | 522 | 331 |
| Below Normal Water Years | 893 | 1026 | 832 | 329 | 80 | 30 | 37 | 69 | 241 | 468 | 824 | 1302 |
| Dry Water Years | 988 | 1183 | 914 | 563 | 191 | 81 | 100 | 178 | 372 | 750 | 1140 | 1586 |
| Critical Water Years | 1547 | 1572 | 1166 | 662 | 303 | 218 | 272 | 498 | 792 | 1037 | 1300 | 1727 |

Table 5A-14c. San Joaquin River at Antioch, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | -1 | 1 | -3 | 3 | -57 | -19 | -4 | 122 | 105 | 12 | 3 | 2 |
| 1% | 0 | 0 | -4 | 4 | -8 | -9 | 2 | -16 | 3 | 11 | 8 | -11 |
| 5% | -21 | 17 | -47 | -9 | -36 | -8 | 8 | 11 | 7 | 7 | -10 | 19 |
| 10% | 0 | 5 | 5 | -25 | 24 | -38 | 10 | 24 | 33 | 4 | -14 | -7 |
| 25% | 23 | 17 | -4 | 27 | 1 | -4 | -13 | -9 | -10 | 2 | 70 | 31 |
| 50% | 111 | 34 | 6 | 2 | 0 | 0 | 0 | 5 | -19 | -5 | -30 | 84 |
| 75% | 7 | -14 | 0 | 0 | 0 | 0 | 0 | 0 | -4 | -9 | 41 | 27 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 |

Table 5A-14d. San Joaquin River at Antioch, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 23 | 5 | -2 | -1 | -4 | -4 | -3 | 4 | -5 | -6 | 17 | 33 |
| Wet Water Years | 27 | 7 | -4 | -5 | -1 | 0 | 0 | 4 | -4 | -2 | 38 | 32 |
| Above Normal Water Years | 7 | -18 | -5 | 3 | 0 | 0 | 0 | 4 | -11 | -8 | 38 | 15 |
| Below Normal Water Years | 24 | 9 | -3 | -5 | -2 | -2 | -3 | 3 | -13 | -21 | -38 | 60 |
| Dry Water Years | 22 | 12 | -2 | 2 | -4 | -9 | -12 | 0 | -8 | -2 | 39 | 39 |
| Critical Water Years | 29 | -1 | 7 | 5 | -14 | -9 | 2 | 9 | 9 | 4 | 4 | 0 |

Table 5A-15a. San Joaquin River at Antioch, Frequency that Monthly Average Chloride Concentration Exceeds 250 milligrams per liter

| Month | Baseline Conditions | Proposed Project |
|--------------|----------------------------|-------------------------|
| January | 39% | 39% |
| February | 16% | 14% |
| March | 8% | 8% |
| April | 10% | 10% |
| May | 17% | 17% |
| June | 45% | 45% |
| July | 62% | 63% |
| August | 93% | 93% |
| September | 91% | 93% |
| October | 71% | 77% |
| November | 91% | 91% |
| December | 71% | 71% |

Table 5A-16a. Contra Costa Water District Pumping Plant #1, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 237 | 261 | 250 | 292 | 175 | 98 | 84 | 83 | 106 | 169 | 167 | 212 |
| 1% | 230 | 250 | 247 | 221 | 172 | 84 | 83 | 81 | 93 | 122 | 164 | 187 |
| 5% | 218 | 233 | 237 | 187 | 126 | 73 | 74 | 73 | 80 | 100 | 129 | 172 |
| 10% | 196 | 217 | 224 | 171 | 109 | 56 | 60 | 64 | 52 | 88 | 121 | 166 |
| 25% | 168 | 160 | 206 | 149 | 71 | 39 | 49 | 50 | 29 | 51 | 96 | 142 |
| 50% | 136 | 132 | 163 | 88 | 39 | 32 | 38 | 37 | 26 | 34 | 60 | 115 |
| 75% | 23 | 46 | 88 | 32 | 28 | 28 | 30 | 26 | 21 | 21 | 30 | 37 |
| 99.9% | 17 | 19 | 20 | 8 | 9 | 7 | 6 | 6 | 6 | 12 | 14 | 16 |

Table 5A-16b. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 106 | 115 | 147 | 95 | 54 | 36 | 41 | 39 | 30 | 43 | 66 | 97 |
| Wet Water Years | 90 | 96 | 96 | 45 | 37 | 29 | 27 | 20 | 17 | 19 | 28 | 33 |
| Above Normal Water Years | 112 | 123 | 159 | 78 | 41 | 35 | 43 | 31 | 23 | 22 | 32 | 38 |
| Below Normal Water Years | 93 | 101 | 153 | 102 | 48 | 33 | 49 | 47 | 26 | 41 | 79 | 144 |
| Dry Water Years | 99 | 111 | 175 | 127 | 73 | 37 | 42 | 47 | 32 | 59 | 98 | 129 |
| Critical Water Years | 158 | 171 | 190 | 144 | 80 | 54 | 53 | 55 | 64 | 82 | 103 | 153 |

Table 5A-17a. Contra Costa Water District Pumping Plant #1, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 237 | 263 | 251 | 292 | 173 | 94 | 84 | 76 | 121 | 165 | 156 | 212 |
| 1% | 227 | 250 | 247 | 221 | 140 | 87 | 83 | 75 | 93 | 122 | 150 | 184 |
| 5% | 219 | 228 | 234 | 190 | 126 | 72 | 71 | 66 | 83 | 100 | 139 | 169 |
| 10% | 196 | 217 | 226 | 176 | 108 | 58 | 62 | 56 | 54 | 88 | 123 | 162 |
| 25% | 168 | 168 | 205 | 149 | 72 | 40 | 53 | 46 | 29 | 51 | 97 | 147 |
| 50% | 139 | 136 | 164 | 86 | 41 | 33 | 40 | 36 | 25 | 32 | 64 | 124 |
| 75% | 24 | 45 | 88 | 32 | 29 | 28 | 28 | 23 | 21 | 21 | 35 | 46 |
| 99.9% | 17 | 19 | 20 | 8 | 9 | 7 | 6 | 6 | 6 | 12 | 14 | 16 |

Table 5A-17b. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 108 | 116 | 148 | 95 | 55 | 37 | 42 | 36 | 30 | 42 | 69 | 101 |
| Wet Water Years | 92 | 98 | 96 | 45 | 37 | 30 | 26 | 19 | 17 | 19 | 30 | 39 |
| Above Normal Water Years | 114 | 122 | 160 | 81 | 42 | 37 | 40 | 27 | 23 | 22 | 37 | 45 |
| Below Normal Water Years | 95 | 101 | 154 | 102 | 49 | 36 | 54 | 42 | 26 | 40 | 81 | 142 |
| Dry Water Years | 99 | 112 | 175 | 124 | 73 | 38 | 44 | 45 | 32 | 58 | 103 | 138 |
| Critical Water Years | 161 | 173 | 191 | 147 | 80 | 53 | 53 | 54 | 64 | 83 | 104 | 153 |

Table 5A-17c. Contra Costa Water District Pumping Plant #1, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 0 | 2 | 1 | 0 | -2 | -4 | -1 | -6 | 15 | -4 | -11 | 0 |
| 1% | -3 | 0 | 0 | -1 | -31 | 2 | 0 | -6 | 0 | 1 | -13 | -3 |
| 5% | 1 | -4 | -3 | 3 | 0 | 0 | -3 | -7 | 3 | 0 | 11 | -3 |
| 10% | -1 | 0 | 2 | 5 | -1 | 3 | 2 | -8 | 2 | 0 | 2 | -3 |
| 25% | 0 | 8 | 0 | 0 | 1 | 1 | 3 | -4 | -1 | 0 | 1 | 5 |
| 50% | 3 | 4 | 1 | -2 | 2 | 1 | 2 | -1 | -1 | -2 | 4 | 10 |
| 75% | 1 | -1 | 0 | 0 | 1 | 1 | -2 | -3 | 0 | 0 | 5 | 8 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table 5A-17d. Contra Costa Water District Pumping Plant #1, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 1 | 1 | 0 | 0 | 1 | 1 | 1 | -3 | 0 | 0 | 3 | 4 |
| Wet Water Years | 2 | 2 | 0 | 0 | 0 | 1 | -1 | -1 | 0 | 0 | 2 | 6 |
| Above Normal Water Years | 2 | -1 | 1 | 3 | 2 | 2 | -3 | -4 | 0 | 0 | 6 | 7 |
| Below Normal Water Years | 1 | 1 | 1 | 0 | 1 | 3 | 5 | -5 | -1 | -2 | 1 | -2 |
| Dry Water Years | 0 | 1 | 0 | -3 | 0 | 1 | 2 | -2 | 0 | -1 | 5 | 9 |
| Critical Water Years | 2 | 1 | 0 | 3 | 1 | -1 | -1 | -1 | 0 | 1 | 1 | 1 |

Table 5A-18a. Old River at State Route 4, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 186 | 207 | 216 | 248 | 176 | 116 | 111 | 98 | 94 | 137 | 140 | 170 |
| 1% | 181 | 202 | 213 | 192 | 176 | 112 | 108 | 97 | 92 | 105 | 135 | 152 |
| 5% | 169 | 192 | 204 | 183 | 134 | 98 | 94 | 89 | 81 | 93 | 107 | 139 |
| 10% | 154 | 179 | 191 | 171 | 116 | 74 | 87 | 86 | 68 | 79 | 101 | 133 |
| 25% | 138 | 136 | 178 | 148 | 89 | 60 | 79 | 74 | 41 | 49 | 81 | 113 |
| 50% | 117 | 113 | 146 | 107 | 62 | 52 | 60 | 57 | 33 | 36 | 50 | 90 |
| 75% | 26 | 39 | 96 | 50 | 44 | 44 | 50 | 32 | 26 | 23 | 28 | 36 |
| 99.9% | 18 | 22 | 18 | 6 | 6 | 5 | 4 | 4 | 4 | 14 | 15 | 18 |

Table 5A-18b. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 89 | 98 | 133 | 102 | 70 | 54 | 60 | 54 | 37 | 41 | 57 | 80 |
| Wet Water Years | 78 | 84 | 95 | 61 | 50 | 41 | 38 | 27 | 21 | 21 | 27 | 32 |
| Above Normal Water Years | 94 | 103 | 146 | 96 | 61 | 57 | 64 | 48 | 28 | 24 | 29 | 37 |
| Below Normal Water Years | 80 | 87 | 134 | 108 | 67 | 53 | 63 | 58 | 35 | 38 | 65 | 116 |
| Dry Water Years | 85 | 94 | 152 | 127 | 87 | 55 | 70 | 71 | 41 | 52 | 82 | 105 |
| Critical Water Years | 127 | 142 | 169 | 144 | 94 | 74 | 79 | 75 | 71 | 77 | 88 | 121 |

Table 5A-19a. Old River at State Route 4, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 186 | 207 | 216 | 248 | 175 | 114 | 112 | 99 | 105 | 135 | 130 | 170 |
| 1% | 177 | 203 | 213 | 196 | 168 | 114 | 107 | 97 | 90 | 105 | 126 | 148 |
| 5% | 169 | 191 | 201 | 180 | 132 | 95 | 95 | 89 | 82 | 89 | 116 | 135 |
| 10% | 156 | 181 | 194 | 169 | 117 | 76 | 89 | 83 | 67 | 80 | 102 | 128 |
| 25% | 139 | 141 | 177 | 147 | 92 | 65 | 83 | 73 | 40 | 50 | 83 | 118 |
| 50% | 117 | 114 | 147 | 103 | 64 | 54 | 63 | 57 | 32 | 34 | 54 | 101 |
| 75% | 27 | 39 | 98 | 51 | 45 | 46 | 43 | 29 | 27 | 23 | 30 | 43 |
| 99.9% | 18 | 22 | 18 | 6 | 6 | 6 | 4 | 4 | 4 | 14 | 15 | 17 |

Table 5A-19b. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 91 | 99 | 133 | 103 | 72 | 56 | 61 | 53 | 37 | 40 | 59 | 84 |
| Wet Water Years | 79 | 86 | 95 | 61 | 50 | 41 | 35 | 24 | 21 | 21 | 28 | 37 |
| Above Normal Water Years | 96 | 102 | 146 | 99 | 64 | 61 | 67 | 41 | 28 | 24 | 33 | 43 |
| Below Normal Water Years | 81 | 88 | 135 | 108 | 70 | 60 | 70 | 66 | 34 | 36 | 66 | 114 |
| Dry Water Years | 86 | 94 | 152 | 124 | 89 | 58 | 74 | 71 | 41 | 51 | 85 | 112 |
| Critical Water Years | 129 | 143 | 169 | 147 | 96 | 75 | 79 | 75 | 71 | 78 | 88 | 121 |

Table 5A-19c. Old River at State Route 4, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 0 | 0 | 0 | 0 | -1 | -2 | 1 | 1 | 10 | -2 | -10 | 0 |
| 1% | -4 | 1 | 0 | 4 | -8 | 2 | -1 | 1 | -2 | 0 | -9 | -3 |
| 5% | 0 | -1 | -2 | -3 | -2 | -2 | 1 | 0 | 2 | -3 | 9 | -5 |
| 10% | 3 | 2 | 3 | -2 | 1 | 2 | 2 | -2 | -1 | 1 | 1 | -6 |
| 25% | 1 | 6 | -1 | -2 | 4 | 5 | 4 | -2 | -2 | 1 | 2 | 5 |
| 50% | 1 | 1 | 1 | -4 | 3 | 3 | 3 | 1 | -1 | -2 | 4 | 10 |
| 75% | 1 | 0 | 2 | 1 | 1 | 2 | -6 | -3 | 0 | 0 | 2 | 7 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Table 5A-19d. Old River at State Route 4, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 1 | 1 | 0 | 0 | 2 | 3 | 2 | 0 | 0 | 0 | 2 | 3 |
| Wet Water Years | 1 | 2 | 0 | 0 | 1 | 0 | -3 | -4 | 0 | 0 | 1 | 5 |
| Above Normal Water Years | 2 | -1 | 0 | 3 | 3 | 4 | 2 | -8 | 0 | 0 | 4 | 6 |
| Below Normal Water Years | 1 | 0 | 1 | 1 | 3 | 6 | 7 | 7 | -1 | -1 | 1 | -2 |
| Dry Water Years | 0 | 0 | 0 | -3 | 2 | 3 | 4 | 0 | 0 | -1 | 3 | 7 |
| Critical Water Years | 2 | 1 | 0 | 3 | 2 | 1 | -1 | 0 | 0 | 1 | 0 | 0 |

Table 5A-20a. Victoria Canal, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|----------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.1% | 130 | 151 | 163 | 186 | 171 | 155 | 128 | 113 | 81 | 73 | 82 | 111 |
| 1% | 125 | 149 | 158 | 181 | 164 | 131 | 119 | 106 | 74 | 71 | 73 | 82 |
| 5% | 102 | 137 | 141 | 147 | 133 | 115 | 109 | 100 | 72 | 69 | 68 | 76 |
| 10% | 94 | 124 | 130 | 137 | 121 | 104 | 103 | 97 | 66 | 60 | 63 | 72 |
| 25% | 75 | 83 | 115 | 123 | 103 | 85 | 94 | 80 | 48 | 32 | 46 | 60 |
| 50% | 63 | 66 | 99 | 101 | 87 | 75 | 75 | 66 | 41 | 28 | 30 | 47 |
| 75% | 32 | 34 | 73 | 67 | 63 | 61 | 51 | 34 | 30 | 25 | 25 | 28 |
| 99.9% | 20 | 29 | 21 | 7 | 6 | 6 | 4 | 4 | 4 | 11 | 13 | 20 |

Table 5A-20b. Victoria Canal, Monthly Average Chloride (in milligrams per liter), Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Full Simulation Period | 59 | 67 | 95 | 97 | 86 | 74 | 70 | 59 | 40 | 32 | 37 | 46 |
| Wet Water Years | 51 | 56 | 78 | 79 | 66 | 55 | 40 | 29 | 23 | 22 | 24 | 27 |
| Above Normal Water Years | 64 | 74 | 105 | 103 | 93 | 87 | 81 | 56 | 35 | 26 | 24 | 28 |
| Below Normal Water Years | 55 | 60 | 90 | 95 | 90 | 82 | 75 | 65 | 41 | 28 | 32 | 52 |
| Dry Water Years | 57 | 61 | 99 | 103 | 95 | 77 | 86 | 81 | 47 | 33 | 47 | 56 |
| Critical Water Years | 80 | 98 | 121 | 120 | 100 | 89 | 88 | 79 | 66 | 60 | 61 | 74 |

Table 5A-21a. Victoria Canal, Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 130 | 152 | 163 | 186 | 173 | 157 | 133 | 111 | 80 | 73 | 76 | 111 |
| 1% | 125 | 148 | 158 | 180 | 172 | 142 | 124 | 104 | 74 | 72 | 72 | 88 |
| 5% | 102 | 137 | 142 | 146 | 137 | 114 | 114 | 96 | 72 | 69 | 67 | 76 |
| 10% | 92 | 122 | 130 | 136 | 122 | 106 | 108 | 91 | 65 | 61 | 63 | 70 |
| 25% | 77 | 84 | 113 | 124 | 107 | 90 | 96 | 80 | 47 | 32 | 47 | 61 |
| 50% | 66 | 67 | 99 | 100 | 91 | 80 | 78 | 66 | 42 | 28 | 30 | 48 |
| 75% | 32 | 34 | 72 | 67 | 66 | 63 | 50 | 37 | 31 | 25 | 25 | 29 |
| 99.9% | 20 | 29 | 22 | 7 | 6 | 6 | 4 | 4 | 4 | 11 | 13 | 19 |

Table 5A-21b. Victoria Canal, Monthly Average Chloride (in milligrams per liter), Proposed Project

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 60 | 67 | 95 | 97 | 88 | 77 | 73 | 59 | 40 | 32 | 37 | 47 |
| Wet Water Years | 52 | 57 | 78 | 79 | 67 | 54 | 39 | 26 | 23 | 22 | 24 | 27 |
| Above Normal Water Years | 65 | 74 | 105 | 106 | 96 | 90 | 81 | 50 | 35 | 26 | 25 | 29 |
| Below Normal Water Years | 55 | 61 | 91 | 96 | 93 | 87 | 85 | 72 | 40 | 28 | 33 | 52 |
| Dry Water Years | 56 | 60 | 99 | 101 | 98 | 81 | 90 | 80 | 47 | 33 | 47 | 59 |
| Critical Water Years | 81 | 98 | 120 | 122 | 103 | 91 | 88 | 79 | 65 | 60 | 61 | 74 |

Table 5A-21c. Victoria Canal, Difference in Exceedance Probabilities for Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Probability of Exceedance | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|---------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 0.1% | 0 | 1 | 0 | 0 | 2 | 3 | 4 | -2 | -1 | 1 | -5 | 1 |
| 1% | 0 | 0 | 0 | 0 | 8 | 11 | 5 | -3 | 0 | 1 | -1 | 5 |
| 5% | 0 | 0 | 1 | -1 | 4 | -1 | 5 | -4 | 0 | 0 | 0 | 0 |
| 10% | -1 | -1 | 0 | -1 | 1 | 3 | 5 | -6 | -1 | 0 | 0 | -2 |
| 25% | 1 | 1 | -2 | 1 | 3 | 5 | 2 | 0 | -1 | 0 | 1 | 0 |
| 50% | 4 | 1 | 0 | -1 | 4 | 5 | 3 | 0 | 0 | 0 | 0 | 1 |
| 75% | 0 | 0 | -1 | 0 | 3 | 2 | -1 | 3 | 1 | 0 | 0 | 1 |
| 99.9% | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |

Table 5A-21d. Victoria Canal, Difference in Monthly Average Chloride (in milligrams per liter), Proposed Project minus Baseline Conditions

| Average | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|--------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Full Simulation Period | 0 | 0 | 0 | 1 | 2 | 3 | 3 | 0 | 0 | 0 | 0 | 1 |
| Wet Water Years | 0 | 1 | 0 | 0 | 1 | -1 | -1 | -3 | 0 | 0 | 0 | 0 |
| Above Normal Water Years | 1 | 0 | 0 | 2 | 3 | 3 | 0 | -5 | 0 | 0 | 1 | 1 |
| Below Normal Water Years | 1 | 0 | 0 | 1 | 3 | 6 | 10 | 7 | -1 | 0 | 0 | 0 |
| Dry Water Years | -1 | -1 | 0 | -2 | 3 | 5 | 4 | -2 | 0 | 0 | 1 | 3 |
| Critical Water Years | 1 | 1 | 0 | 2 | 3 | 2 | 0 | 0 | -1 | 0 | 0 | 0 |




Figure 5A-1a. Barker Slough at North Bay Aqueduct, Long term Monthly Average Chloride (in milligrams per liter)

Figure 5A-1a shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1b. Barker Slough at North Bay Aqueduct, Wet Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-1b shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model during wet years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1c. Barker Slough at North Bay Aqueduct, Above Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-1c shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model during above normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1d. Barker Slough at North Bay Aqueduct, Below Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-1d shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model during below normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1e. Barker Slough at North Bay Aqueduct, Dry Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-1e shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model during dry years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1f. Barker Slough at North Bay Aqueduct, Critical Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-1f shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model during critical years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1g. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), January

Figure 5A-1g shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in January. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1h. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), February

Figure 5A-1h shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in February. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1i. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), March

Figure 5A-1i shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in March. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1j. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), April

Figure 5A-1j shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in April. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1k. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), May

Figure 5A-1k shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in May. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1l. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), June

Figure 5A-1l shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in June. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1m. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), July

Figure 5A-1m shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in July. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1n. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), August

Figure 5A-1n shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in August. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1o. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), September

Figure 5A-1o shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in September. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1p. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), October

Figure 5A-1p shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in October. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1q. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), November

Figure 5A-1q shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in November. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-1r. Barker Slough at North Bay Aqueduct, Monthly Average Chloride (in milligrams per liter), December

Figure 5A-1r shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Barker Slough at North Bay Aqueduct under the Proposed Project compared to the CalSim 3 100-year model in December. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase at 0% probability of exceedance.




Figure 5A-2a. San Joaquin River at Empire Tract, Long term Monthly Average Chloride (in milligrams per liter)

Figure 5A-2a shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-2b. San Joaquin River at Empire Tract, Wet Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-2b shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model during wet years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase in December and slight decrease in May.




Figure 5A-2c. San Joaquin River at Empire Tract, Above Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-2c shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model for above normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with slight deviations with a decrease in November and an increase in May and August.




Figure 5A-2d. San Joaquin River at Empire Tract, Below Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-2d shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model for below normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with slight deviations with a decrease in October and an increase in March.




Figure 5A-2e. San Joaquin River at Empire Tract, Dry Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-2e shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model for dry years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with slight deviations with a decrease in October and an increase in August and September.




Figure 5A-2f. San Joaquin River at Empire Tract, Critical Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-2f shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model for critical years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with slight deviations with a decrease from November and to March.




Figure 5A-2g. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), January

Figure 5A-2g shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in January. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight decrease from about 3% to 35% exceedance.




Figure 5A-2h. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), February

Figure 5A-2h shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in February. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight decrease from about 0% to 10% exceedance.




Figure 5A-2i. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), March

Figure 5A-2i shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in March. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase from about 8% to 25% exceedance.




Figure 5A-2j. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), April

Figure 5A-2j shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in April. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight decrease from about 2% to 5% exceedance.




Figure 5A-2k. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), May

Figure 5A-2k shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in May. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease from about 0% to 78% exceedance.




Figure 5A-2l. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), June

Figure 5A-2l shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in June. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions.




Figure 5A-2m. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), July

Figure 5A-2m shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in July. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase from about 3% to 12% exceedance.




Figure 5A-2n. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), August

Figure 5A-2n shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in August. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight increase from about 3% to 40% exceedance.




Figure 5A-2o. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), September

Figure 5A-2o shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in September. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight increase from about 40% to 60% exceedance.




Figure 5A-2p. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), October

Figure 5A-2p shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in October. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease from about 18% to 50% exceedance.




Figure 5A-2q. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), November

Figure 5A-2q shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in November. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease from about 20% to 35% exceedance.




Figure 5A-2r. San Joaquin River at Empire Tract, Monthly Average Chloride (in milligrams per liter), December

Figure 5A-2r shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from San Joaquin River at Empire Tract under the Proposed Project compared to the CalSim 3 100-year model in December. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-3a. Banks Pumping Plant, Long term Monthly Average Chloride (in milligrams per liter)

Figure 5A-3a shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-3b. Banks Pumping Plant, Wet Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-3b shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during wet years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase in August and September.




Figure 5A-3c. Banks Pumping Plant, Above Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-3c shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during above normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase in August and September.




Figure 5A-3d. Banks Pumping Plant, Below Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-3d shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during below normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-3e. Banks Pumping Plant, Dry Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-3e shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during dry years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase in August and September.




Figure 5A-3f. Banks Pumping Plant, Critical Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-3f shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during critical years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight decrease in December to February.




Figure 5A-3g. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), January

Figure 5A-3g shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in January. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease from about 10% to 25% exceedance.




Figure 5A-3h. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), February

Figure 5A-3h shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in February. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a quick decline at about 2% to 5 % exceedance and follows the model from there.




Figure 5A-3i. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), March

Figure 5A-3i shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in March. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-3j. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), April

Figure 5A-3j shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in April. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-3k. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), May

Figure 5A-3k shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in March. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease around 52% to 65% exceedance.




Figure 5A-3l. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), June

Figure 5A-3l shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in March. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-3m. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), July

Figure 5A-3k shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in March. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-3n. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), August

Figure 5A-3n shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in August. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight increase from 5% to 15% exceedance and 55% to 85% exceedance.




Figure 5A-3o. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), September

Figure 5A-3o shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in September. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight increase around 50% to 58% exceedance and 60% to 90% exceedance.




Figure 5A-3p. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), October

Figure 5A-3p shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in October. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-3q. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), November

Figure 5A-3q shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in November. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-3r. Banks Pumping Plant, Monthly Average Chloride (in milligrams per liter), December

Figure 5A-3r shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Banks Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in December. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-4a. Jones Pumping Plant, Long term Monthly Average Chloride (in milligrams per liter)

Figure 5A-4a shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-4b. Jones Pumping Plant, Wet Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-4b shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during wet years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase in August to September.




Figure 5A-4c. Jones Pumping Plant, Above Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-4c shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during above normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase in August to September.




Figure 5A-4d. Jones Pumping Plant, Below Normal Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-4d shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during below normal years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions in all months.




Figure 5A-4e. Jones Pumping Plant, Dry Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-4e shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during dry years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight increase in August to September.




Figure 5A-4f. Jones Pumping Plant, Critical Year Monthly Average Chloride (in milligrams per liter)

Figure 5A-4f shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model during critical years. Concentrations are depicted from October (left) to September (right). The line graph shows that the Proposed Project would generally remain like chloride concentrations under the Baseline Conditions with a slight decrease from December to February.




Figure 5A-4g. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), January

Figure 5A-4g shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in January. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease from about 8% to 20% exceedance.




Figure 5A-4h. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), February

Figure 5A-4h shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in February. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease from about 2% to 7% exceedance.




Figure 5A-4i. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), March

Figure 5A-4i shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in March. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-4j. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), April

Figure 5A-4j shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in April. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-4k. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), May

Figure 5A-4k shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in May. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight decrease from about 52% to 65% exceedance.




Figure 5A-4l. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), June

Figure 5A-4l shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in June. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-4m. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), July

Figure 5A-4m shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in July. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight increase from about 5% to 9% exceedance.




Figure 5A-4n. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), August

Figure 5A-4n shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in August. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-4o. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), September

Figure 5A-4o shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in September. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions with a slight increase from about 45% to 55% exceedance.




Figure 5A-4p. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), October

Figure 5A-4p shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in October. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-4q. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), November

Figure 5A-4q shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in November. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-4r. Jones Pumping Plant, Monthly Average Chloride (in milligrams per liter), December

Figure 5A-4r shows the average chloride concentrations, from 0 mg/L to 35 mg/L, from Jones Pumping Plant under the Proposed Project compared to the CalSim 3 100-year model in December. The probability of exceedance ranges from 0% (left) to 100% (right). The line graph shows that the Proposed Project would generally follow the same curvature of the chloride concentrations under the Baseline Conditions.




Figure 5A-5a. San Joaquin River at Antioch, Long term Monthly Average Chloride (in milligrams per liter)




Figure 5A-5b. San Joaquin River at Antioch, Wet Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-5c. San Joaquin River at Antioch, Above Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-5d. San Joaquin River at Antioch, Below Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-5e. San Joaquin River at Antioch, Dry Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-5f. San Joaquin River at Antioch, Critical Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-5g. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), January




Figure 5A-5h. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), February




Figure 5A-5i. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), March




Figure 5A-5j. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), April




Figure 5A-5k. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), May




Figure 5A-5l. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), June




Figure 5A-5m. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), July




Figure 5A-5n. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), August




Figure 5A-5o. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), September




Figure 5A-5p. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), October




Figure 5A-5q. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), November




Figure 5A-5r. San Joaquin River at Antioch, Monthly Average Chloride (in milligrams per liter), December




Figure 5A-6a. Contra Costa Water District Pumping Plant #1, Long term Monthly Average Chloride (in milligrams per liter)




Figure 5A-6b. Contra Costa Water District Pumping Plant #1, Wet Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-6c. Contra Costa Water District Pumping Plant #1, Above Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-6d. Contra Costa Water District Pumping Plant #1, Below Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-6e. Contra Costa Water District Pumping Plant #1, Dry Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-6f. Contra Costa Water District Pumping Plant #1, Critical Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-6g. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), January




Figure 5A-6h. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), February




Figure 5A-6i. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), March




Figure 5A-6j. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), April




Figure 5A-6k. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), May




Figure 5A-6l. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), June




Figure 5A-6m. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), July




Figure 5A-6n. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), August




Figure 5A-6o. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), September




Figure 5A-6p. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), October




Figure 5A-6q. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), November




Figure 5A-6r. Contra Costa Water District Pumping Plant #1, Monthly Average Chloride (in milligrams per liter), December




Figure 5A-7a. Old River at State Route 4, Long term Monthly Average Chloride (in milligrams per liter)




Figure 5A-7b. Old River at State Route 4, Wet Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-7c. Old River at State Route 4, Above Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-7d. Old River at State Route 4, Below Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-7e. Old River at State Route 4, Dry Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-7f. Old River at State Route 4, Critical Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-7g. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), January




Figure 5A-7h. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), February




Figure 5A-7i. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), March




Figure 5A-7j. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), April




Figure 5A-7k. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), May




Figure 5A-7l. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), June




Figure 5A-7m. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), July




Figure 5A-7n. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), August




Figure 5A-7o. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), September




Figure 5A-7p. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), October




Figure 5A-7q. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), November




Figure 5A-7r. Old River at State Route 4, Monthly Average Chloride (in milligrams per liter), December




Figure 5A-8a. Victoria Canal, Long term Monthly Average Chloride (in milligrams per liter)




Figure 5A-8b. Victoria Canal, Wet Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-8c. Victoria Canal, Above Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-8d. Victoria Canal, Below Normal Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-8e. Victoria Canal, Dry Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-8f. Victoria Canal, Critical Year Monthly Average Chloride (in milligrams per liter)




Figure 5A-8g. Victoria Canal, Monthly Average Chloride (in milligrams per liter), January




Figure 5A-8h. Victoria Canal, Monthly Average Chloride (in milligrams per liter), February




Figure 5A-8i. Victoria Canal, Monthly Average Chloride (in milligrams per liter), March




Figure 5A-8j. Victoria Canal, Monthly Average Chloride (in milligrams per liter), April




Figure 5A-8k. Victoria Canal, Monthly Average Chloride (in milligrams per liter), May




Figure 5A-8l. Victoria Canal, Monthly Average Chloride (in milligrams per liter), June




Figure 5A-8m. Victoria Canal, Monthly Average Chloride (in milligrams per liter), July




Figure 5A-8n. Victoria Canal, Monthly Average Chloride (in milligrams per liter), August




Figure 5A-8o. Victoria Canal, Monthly Average Chloride (in milligrams per liter), September




Figure 5A-8p. Victoria Canal, Monthly Average Chloride (in milligrams per liter), October




Figure 5A-8q. Victoria Canal, Monthly Average Chloride (in milligrams per liter), November




Figure 5A-8r. Victoria Canal, Monthly Average Chloride (in milligrams per liter), December